



To: HALCROW INTERNATIONAL PARTNERSHIP DEWA App.No: 11003352

Client : Etihad Rail . Revision :

Project No.: C0306 Date: 13.12.2020

Application Type: Electrical Sub-Contractor Approval (Cable Diversion work) Project Type: General Projects

Project: ETIHAD RAIL PROJECT # C0306 PACKAGE 2C

Subject: PREQUALIFICATION OF M/S ARAR UTILITY CO. (L.L.C.) FOR DEWA (ED) 33 KVWORKS

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* No Objection for M/s ARAR UTILITY CO.L.L.C. P.O.BOX # 231740, Dubai U.A.E. to work as the electrical subcontractor for DEWA (ED) 33kv cable Diversion works in the above project only.
- \* Shop drawing NOC application for the HV cables diversion work to be submitted by the above electrical subcontractor only. The same should be submitted as per DEWA standard to enable DEWA to issue the Estimate cost for the supervision, testing and commissioning charges prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: Prem Kumar Ramamurthy

NOTE: This is a computer generated document and may not require any signature.



For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae







Signature monature in secretary a water





To: HALCROW INTERNATIONAL PARTNERSHIP **DEWA App.No:** 11003026

Client: Etihad Rail Revision: Revision 2

Date: 28.07.2020 Project No.: C0306

Application Type: Electrical Sub-Contractor Approval (Cable Diversion work) Project Type: General Projects

Project: ETIHAD RAIL PROJECT # C0306 PACKAGE 2C

Subject: Prequalification of M/s ARAR UTILITY CO. (L.L.C.) for DEWA (ED) 11kvWorks-Subcontractor.

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) 11KV Power Cable laying works in the above project only.
- Shop drawing NOC application for the HV cables diversion work to be submitted by the above electrical subcontractor only. The same should be submitted as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: Sameh Abd Allatif Amin

NOTE: This is a computer generated document and may not require any signature.



For generations to come

OUR VISION: A sustainable innovative world-class utility.

**Dubai Electricity & Water Authority** PO Box 564, Dubai, UAE, Tel +971 4 324 4444 dewa@dewa.gov.ae













Date:	21st Aug 2019	No. of Pages (including this sheet)	Page	1	Of	1	
-------	---------------	-------------------------------------	------	---	----	---	--

То	CDM Smith	Our Ref:	PTD-R1020/1B-0002-2019
Fax No:	043242057		R1020/1B:-132kV Cable Diversion for Dubai Al
Attn:	Mr.Walid Hasan - Sr. Resident	Subject:	Ain Road upgradation project.  Approval of proposed 132kV Cable Diversion
7 (ссії	Engineer		works Contractor.

Reference to your letter (Ref NO:-R1020-1B/CDMS/19/DEW-MK/0003 dated 29.06.2019) on the subject matter please be informed that Main contractor (M/s GUNAL Construction LLC) proposal of **M/s ARAR Utility** for execution of 132kV Cable diversion works for the cited project is **acceptable**.

However, CDM Smith to ensure that Cable diversion works are carried out in line with DEWA specification & requirement.

This is for your information & further action.

Najla Hassan Ali Al Mazmi

**Project Manager - Projects Transmission** 

(Signed on 21-08-2019 08:42:18)











17<sup>th</sup> Mar 2019 PTD-G2-1160-2019

Mr. Shahab Lutfi
Chief Executive Officer

M/s The Galleria Investments LLC

# Sub: 132kV Cable Diversion Works (EMRT-HLDY): Approval of Cable Contractor M/s ARAR Utility Company L.L.C

With reference to developer letter Ref. No.: GI17-04/0046 dated 14/02/2019 and above-mentioned subject, please refer to the below table for the approval status of the proposed cable contractor for EMRT-HLDY 132kV Cable Diversion Project for Plot Nos. 3350213 and 3356237.

No.	Contractor	Approval Status
1	M/s. ARAR Utility Company L.L.C	Approved

Please note that above approval is subjected to provision of dedicated resources for the project.

This is for your information and necessary action, please.

HAIFA ISMAIL MOHAMMAD SHARIF

**Projects Manager - Projects Transmission** 

PR# 22692 (Signed on 17-03-2019 12:33:00)













Date: 23 <sup>rd</sup> Apr 2018	No. of Pages (including this sheet)	Page	1	Of	3
---------------------------------	-------------------------------------	------	---	----	---

То	M/s. AECOM	Our Ref:	PTD-R1048/4-0003-2018
Fax No:	044391000		R1048/4 - Improvement of EXPO
Attn:	Mr. Adel Elfahham-Resident Engineer	Subject:	2020 Road Networks: Subcontractor Approval

With reference to your letter [ref: SDX-EX4-CIV-LTR-BAH-Y18-00397 dated 08.04.2018], the proposed subcontractor M/s. ARAR Utility Co.LLC, Dubai is approved as 132kV Cable Laying contractor for the subject Cable diversion works for 132kV GRDN-DADM Cable circuit.

Contractor should follow all DEWA specification & working procedure throughout the execution of thie cable diversion project.

Contract details to be provided as per the template attached.

For your information and necessary action.

Vadivelu Elavalagan

V. Elandeger

**Deputy Sr. Manager - Projects Transmission** 

(Signed on 23-04-2018 10:26:17)

CC: M/s. RTA (Eng. Adel Mohammed Al Marzooqi – Director of ROW Dept.)











**DEWA Ref No: 11000124** 

Date: 03.11.2016

To:

SAEED&MOHAMMED(ALNABOODAH ENGINEERI

Application Type: Electrical Sub-Contratcor Approval ( Cable Diversion work )

Project:

SATWA ZONE'S DEVELOPMENT-ROADS AND INFRASTRUCTURE

Subject:

PROPOSED 132 KV DEWA-ED APPROVED CONTRACTOR

Reference to your application regarding the above mentioned subject. Your application has been approved subject to the following comments:

- We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) EHV 132kv Cable Diversion works in the above project only.
- M/s. ARAR shall submit a separate dedicated organization chart specific to this project for DEWA review/approval at DEWA - Warsan Complex - First floor - ProjectsTransmission Department (PTD).
- M/s. ARAR shall confirm that this will not have any impact on the running DEWA projects schedule due to resource assignment by M/s ARAR.

Issued By : Eng. Amina Ali Hashem

Senior Manager-Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

Page 1 of 1



هیئة کهرباء ومیاه دبی ص.ب. 564 دبی. إ.ع.م. ھاتف: 4444 324 9714+ فاكس: 8111 9714+ dewa@dewa.gov.ae

EXPO 2020 QuuŚ! DUBALUNTED ARAB EMPATES



Tel +9714 324 4444 Fax +9714 324 8111

**Dubai Electricity & Water Authority** 

PO Box 564, Dubai, UAE

OUR VISION: A Sustainable Innovative World-Class Utility. ولا المعنيين وتعزيز ويقد دبي من خلال تقديم خدمات مستدامة للكورباء (DURMISSION: We are committed to the happiness of our stakeholders and promoting Dubai's vision through the delivery of sustainable electricity and water at a wold-class level of reliability, efficiency and, safety in an environment that nurtures innovation with acompetent workforce and effective partnerships; supporting resources sustainability.

رؤيتنا: مؤسسة مستدامة مُبتكِرة على مستوى عالمي.





Date <b>23-03-2015</b>	ase 397/15	No. of Pages (including this sheet)	Page	1 0	1
To: M/s. Parsons	Our Ref. :	II&P/TS&C/SCA/F/0186/2015	13   13   13   12	2 10 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
Fax No : <b>04 – 280 33</b>	Subject :	R777/3C2 – Improvements to Wafi	Interchan	ge	
Attention : Adel Moha	PETERSON PETERSON NAMED IN THE PETERSON NAME	Prequalification Document for M/s. contractor) for 11, 33,132 kv Works		ility Co. (Sub-	

Reference to your letter ref: 206/R777/3C2/15R0004 dated 18<sup>th</sup> March 2015, which was received by DEWA on 22<sup>nd</sup> March 2015, regarding the above subject please be informed that, we have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) Electrical Cabling works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

Note3: Works of 132KV for slewing pilot cables only.

This is for your information & necessary action please.

Eng. Amina Ali Hashem
SM - Infrastructure Information & Permits











23/3/2015

PROJECT: 2823 - EXTERNAL ACCESS ROADS TO PROPOSED COMMERCIAL BUILDING ON PLOT NO.4237986 AT AL WARQA THIRD, DUBAI, UAE

PIE-20201002-PQN-0007 R01



Submitted by (Contractor):





# PREQUALIFICATION SUBMITTAL We submit the following Prequalification pocument for approval PROSCAPE LLC RECEIVED PIE20201002, Ext. Access Road to Prop Comm P.O. Box: 3151, DUBAI, UAE 19 MAR 2020 Date: 18.03.2020

		CONTRACTOR CHANGE	S NEW D	60 4 1B
Sr No.	Title		Copies	Remarks
1	Prequalification Document for ARAR UTILITY Co. LLC		02	
	For (Electrical Works)			
	Scope : 132 KV Protection Works, Cable Lowering, Duct Laying	&		
	Backfilling			
				10 11 12 13/14
			6	RECEIVED
			6 7	24 MAR 2020
			The state of the s	PROSCAPELIC O
			1/4	3/1/2012/22
	ved by (Consultant): Date: oval Status			1100/201
Appr	Approved Approved as Noted	9		Rejected
Com	ments: NO OPSIECTION, SCORPECT	O SMI	ICT (	COMPLIANCE
017	POTHOUTHES REGULATIONS & CONTRACT REQUIREMENT	KIRACT	Spor	FIRICATION
1	102-1202 MANCE IS ALSO SCORY	ECT 70	3/01	PRINOPLY
UN	WALL STINGS LY LOUIS CONTURE WAR	15,68	NOV	INEE12'S
DE	3012ETTON. STININ HIGGILOUPLE	34 11/E	6/-1	5141 6
RE	SPECTIVE APOTTIONITY · DEOVAL &+	A. ACG	DRO	inely.
Resi	dent Engineer: Date: 24/	23/202	20.	Time!
RECE	IVED FOR CONTRACTORNS	01 = 0		
Sign	ature: P.O.Boy 11676 - P.Ullin S.A.E 16 P.O.Boy 11676 - P.O.Bo			Time:

Distribution cc:

Surveyor Quantity Surveyor

Inspector





To: PARSONS OVERSEAS LIMITED (DUBAI BRANCH) DEWA App.No: 11002678

Client: DUBAI ROADS & TRANSPORT AUTHORITY. Revision: Revision: 1

Project No.: R1060/1B Date: 12.03.2020

Application Type: Electrical Sub-Contractor Approval (Cable Diversion work) Project Type: Road Projects

Project: DEVELOPMENT OF SHEIKH RASHID BIN SAEED CORRIDOR (NAD AL HAMAR I/C TOE311)

Subject: Prequalification of M/s ARAR UTILITY CO. (L.L.C.) for DEWA (ED) works

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) 11KV & 33KV Cable Diversion works in the above project only.
- \* Shop drawing NOC application for the HV cables diversion work to be submitted by the above electrical subcontractor only. The same should be submitted as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: Khadija Mohamed R. Banihammad NOTE: This is a computer generated document and may not require any signature.



#### Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae











To: CDM SMITH INC DEWA App.No: 11002101

Client: DUBAI ROADS & TRANSPORT AUTHORITY Revision:

Project No.: R1020/1B Date: 30.06.2019

Application Type: Electrical Sub-Contratcor Approval (Cable Diversion work) Project Type: Road Projects

Project: R1020/1B - UPGRADE OF DUBAI AL AIN ROAD, CONTRACT 1B

Subject: REQUEST FOR APPROVAL OF SUB-CONTRACTOR M/S ARAR UTILITY FOR 6.6KV, 11KV AND

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) 6.6, 11 & 33KV Cable Diversion works in the above project only with the following condition.
- \* Submit shop drawing for relocation of cables as per DEWA standard to enable us to issue the estimate cost for the supervision, testing and commissioning charges prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager-Infrastructure Information and Permits

Prepared by: IMRAN SHAHID

NOTE: This is a computer generated document and may not require any signature.

Dubal To July Och Jul

Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae









To: PARSONS OVERSEAS LIMITED (DUBAI BRANCH)

**DEWA App.No:** 11002645

Client: MERAAS ESTATE (LLC).

Revision: Revision 1

Project No.: MH0021

Date: 17.02.2020

Application Type: Electrical Sub-Contractor Approval (Cable Diversion work) Project Type: Road Projects

Project: MH0021 - CONSTRUCTION OF JEBEL ALI LABOR CITY ROADS

Subject: APPROVAL OF SUBCONTRACTOR (ARAR UTILITIES) FOR 11 KV WORKS

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### Comments:

- \* No Objection for M/s ARAR Utility Company to work as the electrical subcontractor for DEWA (ED) 11kv cable Diversion works in the above project only.
- \* Shop drawing NOC application for the HV cables diversion work to be submitted by the above electrical subcontractor only. The same should be submitted as per DEWA standard to enable DEWA to issue the Estimate cost for the supervision, testing and commissioning charges prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: Prem Kumar Ramamurthy

NOTE: This is a computer generated document and may not require any signature.



#### Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

**Dubai Electricity & Water Authority** PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae







www.dewa.gov.ae





To: ARAR UTILITY CO. LLC DEWA App.No: 11001761

Client: ARARUTILITY CO LLC Revision:

Project No.: NIL Date: 18.02.2019

Application Type: Electrical Sub-Contratcor Approval (Cable Diversion work) Project Type: General Projects

**Project: EXISTING CITY TOWER 1** 

Subject: Prequalification of M/s ARAR UTILITY CO. (L.L.C.) for DEWA (ED) works- Subcontractor.

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11 KV Cable Diversion works in the above project only.
- \* You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.
- \* For 132Kv cable diversion/ modification and outage related works, approval to be obtained from Transmission Projects (PTD).

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager-Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

NOTE: This is a computer  $\,$  generated document and may not require any signature.

Dubal reading March Marc

Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae











To: KEO International Consultants LLC DEWA App.No: 11002079

Client: DUBAI ROADS & TRANSPORT AUTHORITY Revision:

Project No.: R1006 Date: 20.06.2019

Application Type: Electrical Sub-Contratcor Approval (Cable Diversion work) Project Type: Road Projects

Project: UPGRADE OF AL KHAWANEEJ ROAD & MUSHRIF PARK CORRIDOR

Subject: M/S. ARAR UTILITY CO FOR SUBCONTRACTOR OF HV 11 KV CABLE DIVERSION WORKS ONLY

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### **Comments:**

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) 11KV, Cable Diversion works in the above project only with the following conditions.
- \* You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable us to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager-Infrastructure Information and Permits

Prepared by: IMRAN SHAHID

NOTE: This is a computer generated document and may not require any signature.

Dubal Colling Word Water Williams A Mater Williams A Mate

Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae











To: DUBAI ROADS & TRANSPORT AUTHORITY

DEWA App.No: 11001390

Company: PARSONS OVERSEAS LIMITED (DUBAI BRANCH)

Date: 09.08.2018

Project: R1046 IMPROVEMENTS OF THE AL QUDRA ROAD INTERSECTION Project Type: Road Projects

Application Type: Electrical Sub-Contratcor Approval ( Cable Diversion work )

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### Comments:

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) 11KV, 33KV Power Cable cable Diversion works in the above project only with the following conditions.
- \* You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

NOTE: This is a computer generated document and may not require any signature.





Page 1 of 1

For generations to come

OUR VISION. A sustainable innovative world class utility.

Dubai Electricity & Water Authority POBOX 564, Buban, MAE. Tel +971 4 324 4444 devoérdees goves











**DEWA Ref No: 11000415** Date: 09.03.2017

To: HALCROW INTERNATIONAL PARTNERSHIP

Application Type: Electrical Sub-Contratcor Approval ( Cable Diversion work )

Project: **ROUTE 2020 METRO PROJECT** 

Pregualification of M/s ARAR UTILITY CO. (L.L.C.) for DEWA (ED) works- Subcontractor. Subject:

Reference to your application regarding the above mentioned subject. Your application has been approved subject to the following comments:

#### Comments:

- We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 33KV, 11KV, 6.6KV Power Cable & 33KV Pilot cable Diversion works in the above project only with the following conditions.
- You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

Issued By : Eng. Amina Ali Hashem Senior Manager- Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

Page 1 of 1



هیئة کهرباء ومیاه دبي ص.ب. 564 دبي، إ.ع.م. هاتف: 4444 324 4714 + 9714 فاكس: 8111 9714 + dewa@dewa.gov.ae



PO Box 564, Dubai, UAE Tel +9714 324 4444 Fax +9714 324 8111 dewa@dewa.gov.ae

OUR VISION: A Sustainable Innovative World-Class Utility.

رَقَّتِنَا: مؤسسة مستدامة مُبتكِرة على مستوى عالمي.

OUR MISSION: We are committed to the happiness of our stakeholders and promoting Dubai's vision through the delivery of sustainable electricity and water at a world-class level of reliability, efficiency and, safety in an environment that nurtures innovation with a competent workforce and effective partnerships; supporting resources sustainability

رسالتنا: نلتزم بتحقيق السعادة لكافة المعنيين وتعزيز رؤية دبي من خلال تقديم خدمات مستدامة للكهرباء والمياه بمستوى عالمي من الاعتمادية والكفاءة والسِّلاَّمة ضمَّن بيئة محفزة للابتكار بكادر مؤهل وشراكات فعَّالة، داعمين لديمومةَ الموارد.





اکسبو EXPO 2020 DUBALUNITED ARAB EMIRATE





**DEWA Ref No: 11001108** Date: 11.03.2018

To: PARSONS OVERSEAS LIMITED (DUBAI BRANCH)

Application Type: Electrical Sub-Contratcor Approval (Cable Diversion work)

Project: T0076 DHCC PHASE 1& 2 ROADS AND INFRASTRUCTURE WORKS

Subject: Prequalification of M/s ARAR UTILITY CO.LLC for DEWA (ED)11kv works-Subcontractor

Reference to your application regarding the above mentioned subject. Your application has been approved subject to the following comments:

#### Comments:

- We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11KV Cable works in the above project only as per DEWA Design NOC ref. 100114458 with the following conditions.
- Separate application for 132kv DEWA-ED prequalification to be submitted for DEWA review/approval at DEWA -Warsan Complex - First floor - Projects Transmission Department (PTD).
- You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

Issued By: Eng. Amina Ali Hashem Senior Manager- Infrastructure Information and Permits

Prepared by : SAMEH ABD ALLATIF AMIN

Page 1 of 1


Dubai Electricity & Water Authority PO Box 564, Dubai, UAE Tel +9714 324 4444 Fax +9714 324 8111 dewa@dewa.gov.ae




هیئة کهرباء ومیاه دیج ص.ب. 564 دبي، إ.ع.م. ھاتف: 4444 324 4714 + فاكس: 8111 324 4444 + dewa@dewa.gov.ae



رؤيتنا: مؤسسة مستحامة فُبتكِرة على مستوى عالمي.













To: DUBAI ISLAMIC BANK PJSC DEWA App.No: 11001371

Company: Arcadis Consulting Middle East Limited Date: 23.07.2018

Project : MADAIN AL EMARAT (BADR1) Project Type : Road Projects

Application Type: Electrical Sub-Contratcor Approval (Cable Diversion work)

With reference to your application regarding the above mentioned subject, your application has been approved subject to the following comments:

#### Comments:

- \* We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) LV, 11KV, 33KV Cable Diversion works in the above project only with the following conditions
- \* You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

This is for your information and necessary action.

Issued By: Eng. Amina Ali Hashem

Senior Manager- Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

NOTE: This is a computer generated document and may not require any signature.

Dubal creeding Weak Water Wate

Page 1 of 1

For generations to come

OUR VISION: A sustainable innovative world-class utility.

Dubai Electricity & Water Authority PO Box 564, Dubai, UAE. Tel +971 4 324 4444 dewa@dewa.gov.ae











**DEWA Ref No: 11000847** Date: 31.10.2017

To: **AURECON ENGINEERING INTERNATIONAL (PTY)** 

Application Type: Electrical Sub-Contratcor Approval ( Cable Diversion work )

Project: R1028/1 EXTENSION OF TRIPOLI ROAD AND IMPROVEMENTS OF ALGERIA ROAD

Pregualification of M/s ARAR UTILITY CO. (L.L.C.) for DEWA (ED) works- Subcontractor. Subject:

Reference to your application regarding the above mentioned subject. Your application has been approved subject to the following comments:

- We have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11KV, 6.6KV Cable Diversion works in the above project only with the following conditions.
- You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA to issue the estimate cost for the supervision, testing, commissioning charges and depreciation cost prior to start the work.

Issued By : Eng. Amina Ali Hashem Senior Manager- Infrastructure Information and Permits

Prepared by: SAMEH ABD ALLATIF AMIN

Page 1 of 1



هیئة کهرباء ومیاه دبي ص.ب. 564 دبي، إ.ع.م. هاتف: 4444 324 4714 + 9714 فاكس: 8111 9714 + dewa@dewa.gov.ae


Dubai Electricity & Water Authority

PO Box 564, Dubai, UAE Tel +9714 324 4444 Fax +9714 324 8111 dewa@dewa.gov.ae

OUR MISSION: We are committed to the happiness of our stakeholders and promoting Dubai's

vision through the delivery of sustainable electricity and water at a world-class level of reliability, efficiency and, safety in an environment that nurtures innovation with a competent workforce and

رَقَّتِنَا: مؤسسة مستدامة مُبتكِرة على مستوى عالمي. رسالتنا: نلتزم بتحقيق السعادة لكافة المعنيين وتعزيز رؤية دبي من خلال تقديم خدمات مستدامة للكهرباء والمياه بمستوى عالمي من الاعتمادية والكفاءة والسِّلاَّمة ضمَّن بيئة محفزة للابتكار بكادر مؤهل وشراكات





اکسبو EXPO 2020 DUBALUNITED ARAB EMIRATE



Date <b>07-08-2014</b>		No. of Pages (including this sheet) Page 1 Of 1
To: M/s. Parsons	Our Ref. :	II&P/TS&C/PQ/F/0463/2014
Fax No: 04 – 336 79 20  Attention: Mr. Hisham Ashour Sr. Resident Engineer	Subject :	R881/2D – Comprehensive Improvements of the Parallel Roads- Phase 2D  Pre-Qualification of M/s ARAR Utility Co. LLC for DEWA ED HV

Reference to your letter ref: 206/R881/2D/14R041 dated 17<sup>th</sup> July 2014, regarding the above subject, please be informed that, we have **No Objection** for M/s ARAR to work as electrical subcontractor for DEWA ED HV 11kv Cable works for the above project only.

Note: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information & necessary action please.

Eng. Amina Ali Hashem
SM – Infrastructure Information & Permits

Cc: RTA













F TO JUNE

### **Facsimile Transmission**

Date 15-06-2016	Case No. 1052/16	No. of Pages (including this sheet)	Page 1	1 of 1
To: M/s. Parsons	Our Re	f.: II&P/TS&C/PQ/F/0559/2016		
Fax No : <b>04-336 7</b> 9	20 Subject	R1043/2 Development of Saih Al Salan	n Street – Ph	ase II
Attention Mr. Abdu Resident I	Gaffar Rn. Engineer	Prequalification of M/s ARAR Utility Co 11kv & 33kv Cable Works	o. LLC for DE	WA-ED HV

Reference to your letter ref.: 206/R1043-2/16R001 dated on 14<sup>th</sup> June 2016, which was received by DEWA on 14<sup>th</sup> June 2016, regarding the above subject please be informed that, we have <u>No Objection</u> for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11kv & 33kv Cable Diversion works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

Note3: You are hereby being advised to submit shop drawing for relocation of cables as per DEWA standard to enable DEWA issue the Estimate for the supervision testing, and commissioning charges prior to start the work.

This is for your information and necessary action please.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits

RECEIVED

1 6 JUN 2016

PARSONS SITE OFFICE B1043/2

er en l'ar l'est

لأجبالنا الفصادم قصادما For generations to come

Commence Brown Standard You Washington



Date <b>02-02-2016</b>	Case No 0176/1	No. of Pages (including this sheet) Page 1 of 1
To: M/s Parsons	Ou	r Ref. : II&P/TS&C/PQ/F/0094/2016
Fax No : <b>04 – 336 7</b>	<b>79 20</b> Su	Dject: R921/1B – Improvement of Al Wasl Road – Phase 1B – Interchange 2.5
Attention : Mr. Rabea		Prequalification Document for 11kv & 33kv cable diversion (M/s ARAR Utility Co. LLC)

Reference to your letter ref: 206/R921/1B/16R006 dated 31<sup>st</sup> January 2016, which was received by DEWA on 1<sup>st</sup> February 2016 regarding the above subject; please be informed that, we have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11kv & 33kv Cable Diversion works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information & necessary action please.

Eng. Amina Ali Hashem
SM—Infrastructure Information & Permits













Date   28-12-2015   Case No.	. 1760	No. of Pages (including this sheet)	Page	1	of	1
To: M/s. Parsons	Our Ref.	: II&P/TS&C/PQ/F/0790/2015				
Fax No : <b>04-336 79 20</b>	Subject :	R978/3A: Development of Cycle and J Locations in Dubai (Mirdif, Mushirif, A				
Attention : Peeyush Shukla Director Construction	n	Pre-Qualification Document for M/s A	ARAR for	DEWA -	– ED L\	/ &

Reference to your letter ref: C.2.153/15A4775 dated 21<sup>st</sup> December 2015; which was received by DEWA on 22<sup>th</sup> December 2015; regarding the above subject please be informed that, we have <u>No Objection</u> for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) LV& 11kv Cable works in the above project only.

Note 1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note 2: As built drawing to be submitted for DEWA approval after completing the diversion work.

Note 3: However, for 132KV Cable activity is only approved for Protection Works.

This is for your information and necessary action.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits













Date 14-08-2014	No. of Pages (including this sheet) Page 1 of 1
To: M/s. PARSONS	Our Ref.: II&P/TS&C/SCA/F/0479/2014
Fax No : <b>04-336-7920</b>	Subject: DPDP-PR-5005 ISLAND 2
Attention : Senior Resident Engineer	Approved of Sub-Contractor M/s ARAR Utility Company LLC for Electrical Works LV & HV

We refer to your letter ref: 206/DPDP-PR-5005/14R0006 dated 13<sup>th</sup> August 2014, which was received by DEWA on 13<sup>th</sup> August 2014, regarding the above; please note that we have <u>No Objection</u> for M/s ARAR to works as electrical subcontractor for DEWA ED works for the above project only.

Note: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information & necessary action please.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits

Cc: PED















Date <b>23-06-2014</b>		No. of Pages (including this sheet)	Page	1	of	1
To: M/s. Parsons	Our Ref. :	II&P/TS&C/PQ/F/0375/2014				
Fax No : 04 – 325 67 32	Subject :	R829/3B - Development of Al Qudra	Road - (	South)		
Attention : Mr. Abdul Gaffar Rah Resident Engineer		Pre-Qualification of M/s ARAR Utility Cable Work	y Co. LLC	for DEV	VA ED	HV

Reference to your letter ref: 206/R829-3B/14R004 dated 19<sup>th</sup> June 2014, which was received by DEWA on 22<sup>th</sup> June 2014, regarding the above subject, please be informed that your submission did not meet DEWA acceptance criteria, Thus you are requested to submit the number of jointer and manpower to enable us process your request of pre-qualification.

This is for your information & necessary action please.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits

Cc: RTA

















Date <b>25-12-2014</b>	No. of Pages (including this sheet) Page 1 of 1
To: M/s. AQLEH Eng. Consul.	Our Ref. : II&P/TS&C/PQ/F/0765/2014
Fax No : <b>04-339 688 0</b>	Subject: 153-004 - MEYDAN GATED COMMUNITY 153-002 - MEYDAN RACE COURSE VILLAS
Attention : Mohammad Kalloush Resident Engineer	PREQUALIFICATION FOR APPROVAL - M/S ARAR UTILITY Co LLC FOR DEWA-ED CABLING WORKS

Reference to your letter ref: MGC-153-04-206-0365 dated 24<sup>th</sup> December 2014, regarding the above subject please be informed that, we have <u>No Objection</u> for M/s ARAR to work as electrical subcontractor for DEWA (ED) Electrical Cabling works for the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information & necessary action please.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits















Date <b>07-12-2015</b>	Case No. 1668	No. of Pages ( including this sheet)	Page	1	of	1
To: M/s. Louis Be	rger Our F	ef.: <b>II&amp;P/TS&amp;C/PQ/F/0739/2015</b>				
Fax No : <b>04-307</b> 0	<b>1400</b> Subje	ct: R983 - Pedestrian Bridges at Various Bridge # 2 – Al Mina Street	Locations	s in Du	bai –	
Attention : Loucas S Construc	lymeon ction Director	Pre-Qualification Document for M/s Diversion Works - Bridge # 2 – Al Mi		HV Ca	ble	

Reference to your letter ref: **5101091-LB-TC-DEWA-LT-O-15-0024** dated **06<sup>th</sup> December 2015**; which was received by DEWA on **07<sup>th</sup> December 2015**; regarding the above subject please be informed that, we have **No Objection** for **M/s ARAR UTILITY CO**. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11kv &33kv Cable Diversion works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information and necessary action.

SM – Infrastructure Information & Permits















Date <b>23-03-2015</b>	ase:394/15	No. of Pages (including this sheet)	Page	1 of	1
To: M/s. Parsons	Our Ref.	II&P/TS&C/SCA/F/0186/2015	13	2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
Fax No : <b>04 – 280 33</b>	O2 Subject :	R777/3C2 – Improvements to Wafi l	nterchan		
Attention : Adel Mohan Sr. Resident	AT THE PARTY OF TH	Prequalification Document for M/s. contractor) for 11, 33,132 kv Works	ARAR Ut	ility Co. (Sub-	·

Reference to your letter ref: 206/R777/3C2/15R0004 dated 18<sup>th</sup> March 2015, which was received by DEWA on 22<sup>nd</sup> March 2015, regarding the above subject please be informed that, we have No Objection for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) Electrical Cabling works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

Note3: Works of 132KV for slewing pilot cables only.

This is for your information & necessary action please.

Eng. Amina Ali Hashem

SM - Infrastructure Information & Permits











23/3/2015





	Facsi	imile Transmission		4 6		
Date <b>23-03-2015</b>	1.468 396/16	No of Pages (including this sheet)	Page 1	of 1		
To: M/s. Khansa	heb Our Ref.	II&P/TS&C/SCA/F/0187/2015	2   2   2   7   6	WATER		
Fax No : 04 – 28 5:  Attention Sajeev Pa Contract I	vithran	P-457FZ JAFZA CONVENTION CENTER WORKS- PREQUALIFICATION DOCUMENTS FOR DEWA-ED 33/11KV CABLE SLEWING AI	/ ROADS AND	EXTERNAL THE STATE OF THE STATE		

We refer to your letter Ref: KR479\_LTR\_KCE\_DEW\_029 dated 18<sup>th</sup> March 2015, which was received by DEWA on 22<sup>nd</sup> March 2015, regarding the above subject please be informed that, we have <u>No Objection</u> for M/s ARAR UTILITY CO. L.L.C. P.O.BOX — 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11KV, 33KV Electrical Cabling works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your information and necessary action

Eng. Amina Ali Hashem

SM – Infrastructure Information & Permits















Date 19-02-2015 Case	231 15 No. of Pages (including this sheet) Page 1 of 1
To: M/s. Dutco Balfour Beatty	Our Ref. : II&P/TS&C/SCA/F/0097/2015
Fax No : 04-880 14 57	Subject : Downtown Dubai Development – Miscellaneous Infrastructure Works
Attention : Mr. SAI KRISHNA KV Contracts Manager	Diversion of 11kv Cables at Dubai Marina Promenade – District 10

Reference to your letter ref: L/AC7185/8.5.10/SK/NS/nj/2157 dated 18<sup>th</sup> February 2015 which was received by DEWA on 18<sup>th</sup> February 2015, regarding the above subject please be informed that, we have <u>No Objection</u> for M/s ARAR UTILITY CO. L.L.C. P.O.BOX – 231740, Dubai, U.A.E to work as electrical subcontractor for DEWA (ED) HV 11kv Cable Diversion works in the above project only.

Note1: All works shall be executed as per DEWA work instruction for private cable laying works.

Note2: As built drawing to be submitted for DEWA approval after completing the diversion work.

This is for your Information and necessary action.

